

**REGIONAL WATER TESTING LAB, SANGRUR**

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtsangrur@gmail.com

To, \

DR.GAGANDEEP ROTARY PUBLIC SCHOOL  
Jakhepal Road, Sunam


No.: RWTL/SNG/2425/00548 Dated: 15/04/2024

Subject: Testing Reports of Water Samples.

Reference: Your Letter/SRF No. spl-1 Dated: 12/04/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 15/04/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A: Test Report

  
Authorized Signatory  
For, Regional Water Testing Lab  
Sangrur

**REGIONAL WATER TESTING LAB, SANGRUR**  
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtsangrur@gmail.com

**TEST REPORT**

Name & Address of Customer : <b>DR.GAGANDEEP ROTARY PUBLIC SCHOOL</b> Jakhepal Road,Sunam	Customer Reference No.	No : spl-1 Dated : 12/04/2024
	Sample Submitted by	
	Date of Sample Receipt	15/04/2024
	Analysis Starting Date	15/04/2024
	Analysis completion Date	16/04/2024

Discipline : Chemical Testing,Bacteriological Testing	Group: Water
ULR No.:	Sample Type : Treated Water
Test Report No.: RWTL/SNG/2425/00548	Date of Issue : 19/04/2024
Registration no.: RWTL/SNG/REG2425/00037	Condition of Sample : Unsealed
Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth : R.O / NA
Village : Not Mentioned	Habitation : Not Mentioned
Block: Not Mentioned	District : Sangrur
Latitude : Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Iron	BDL	1.0	No Relaxation	mg/l	Spectrophotometric Method
2	Fluoride	BDL	1.0	1.5	mg/l	APHA 4500 F-(23rd Ed. 2017)/IS 3025 (Part 60)
3	Nitrate	BDL	45	No Relaxation	mg/l	Spectrophotometric Method/ APHA 4500 NO3 (23rd Ed. 2017)
4	Total Coliform	ND@37°C	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
5	E-Coli	ND@45°C	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

Note: Detection Limit(Iron:0.01, Fluoride:, Nitrate:, )

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
- \* Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar  
Quality Manager  
Authorized Signatory  
For,Regional Water Testing Lab  
Sangrur

End of the Test Report